



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2024 T/J(262/2024)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

4 June 2024

Delabie Ltd  
21/F, The Phoenix, 23 Luard Road,  
Wan Chai, Hong Kong

(Attn.: Ms Sophie GEFFROY)

Dear Madam,

**Approval of "DELABIE" Sensor Tap  
(General Acceptance No. C20240343)**

Your letters both ref. 378015 dated 22 March 2024 and 7 May 2024 refer.

Having considered the test report ref. J29614Ar1 issued on 24 April 2024 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Delabie SAS  
**Country of Origin:** France  
**Brand:** Delabie  
**Details of Fitting:** 3/8" Deck mounted sensor basin tap with 1 no. of flexible hose approved by UK's WRAS under ref. 2301019  
**Model:** 378015  
**Body Markings:** **DELABIE**  
**Expiry Date:** 31 January 2028

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr Albert CHOW at tel. no. 3583 4086.

Yours faithfully,



(Terry KUNG)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only