



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵遞

e-mail

wsdinfo@wsd.gov.hk

電話

Telephone

2829 4367

圖文傳真

Facsimile

2824 0578

檔號

Reference

(4) in WSD 3321/16 Pt.1 T/J(148)

9 May 2016

Delabie Ltd  
21/F, On Hing Building,  
1 On Hing Terrace,  
Central, Hong Kong

(Attn.: Mr Sebastien Spriet)

Dear Sir,

### Approval of "DELABIE" Combination Tap Assemblies

Your letters ref. HK2446 dated 11 January 2016 and 25 April 2016 refer.

It is noted that the fittings described below have been accepted by the United Kingdom Water Regulations Advisory Scheme (WRAS) to have complied with the requirements of the United Kingdom Water Supply (Water Fittings) Regulations / Scottish Water Byelaws when correctly installed.

**Name of Manufacturer:** Delabie SCS

**Country of Origin:** France

**Brand:** Delabie

**Details of Fitting:** Range of wall mounted, two hole, single outlet (swivel) combination tap assemblies (chromium plated brass), incorporating ceramic cartridge headworks and single lever operating members. The spout outlets incorporate a plastic flow straightener. The inlet offset unions incorporate a servicing valve. The inlets incorporate a plastic flow restrictor. Maximum working pressure 5.0 bar. Maximum operating temperature 60°C.



**Model:** 2446 & 2446L  
**Marking:** Delabie on operating member  
**Size:** ½" x ¾" BSP offset unions

**WRAS Approval Number:** 1512007

**Installation Requirements:** R001, R010, R040

**Expiry Date:** 31 December 2020

In view of the acceptance by WRAS, this Authority has no objection to the use of the said fittings in fresh water supply plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following installation requirements –

“Installation shall comply with the ‘Installation Requirements & Notes’ of the WRAS’s approval letter concerned.” AND

“The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply.”

A condition of this acceptance is that the fittings to be installed should be replicas of the samples certified by WRAS and no modification should be made to the fittings. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water supply plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 2294 2656.

Yours faithfully,



( LAM Ching Man )  
for Water Authority

c.c.      WSD 3321/1/82    ] - without catalogue  
         ME/CS(MC)       ] - with soft copy only